

CITY OF ONIDA
ANNUAL DRINKING WATER QUALITY REPORT
January 1, 2018 – December 31, 2018

WATER QUALITY

The City of Onida has supplied ten consecutive years of safe drinking water to the public it serves and has been awarded the Secretary's Award for Drinking Water Excellence by the South Dakota Department of Environment and Natural Resources. This report is a snapshot of the quality of the water that we provided last year. Included are details about where your water comes from, what it contains and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies.

WATER SOURCE

We serve more than 658 customers an average of 93,000 gallons of water per day. Our water is surface water that we purchase from another water system. The state has performed an assessment of our source water and they have determined that the relative susceptibility rating for the Onida public water supply system is low.

For more information about your water and information on opportunities to participate in public meetings, call (605)258-2441 and ask for Rondha Hiller.

ADDITIONAL INFORMATION

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

***Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

***Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

***Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

***Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

***Radioactive contaminants**, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants can be obtained by calling the Environment Protection Agency's Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Onida public water supply system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Detected Contaminants:

The attached table lists all the drinking water contaminants that we detected during the 2018 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1-December 31, 2018. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

The City of Onida public water system purchases 100% of their water from Mid-Dakota Rural Water (2175).

2018 Table of Detected Contaminants for Onida (EPA ID 0233)

Terms and abbreviations used in the table:

*Maximum Contaminant Level Goal (MCLG): the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Contaminant Level (MCL): the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Action Level (AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.

*Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water. For turbidity, 95% of samples must be less than 0.3 NTU.

*Running Annual Average(RAA): Compliance is calculated using the running annual average of samples from designated monitoring locations.

UNITS

*MFL: million fibers per liter

*mrem/year: millirems per year (a measure of radiation absorbed by the body)

*NTU: Nephelometric Turbidity Units

*pCi/l: picocuries per liter (a measure of radioactivity)

*ppm: parts per million, or milligrams per liter (mg/l)

*ppb: parts per billion, or micrograms per liter (ug/l)

*ppt: parts per trillion, or nanograms per liter

*ppq: parts per quadrillion, or picograms per liter

*pspm: positive samples per month

2018 Table of Detected Contaminants for Mid-Dakota Rural Water (EPA ID 2175)

SUBSTANCE	90% LEVEL	TEST SITES> ACTION LEVEL	DATE TESTED	HIGHEST LEVEL ALLOWED	IDEAL GOAL/UNITS	
Copper	0.5	0	7/26/16	AL=1.3	0 ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	2	0	7/29/16	AL=15	0 ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Substance	Level Detected	Range	Date Tested	Highest Level Allowed (MCL)	Ideal Goal (MCLG)	Major Source of Contaminant
Alpha emitters*	4	ND-4	9/27/16	15	0 pCi/l	Erosion of natural deposits glass and electronics production wastes. erosion of natural deposits.
Fluoride*	0.48		10/23/18	4	4 ppm	Erosion of natural deposits: water additive which promotes strong teeth; discharge from

Haloacetic acids	24.88		11/14/18	60	0 ppb	fertilizer and aluminum factories By-product of drinking water chlorination
Total Trihalomethanes	37.75		11/14/18	80	0 ppb	By-product of drinking water chlorination

Please direct questions regarding this information to Mr. Bill Sarringar with the Mid-Dakota Rural Water public water system at (605)945-0437.

2018 Table of Detected Contaminants for Onida (EPA ID 0233)

Substance	90% Level	Test Sites> Action Level	Date Tested	Highest Level Allowed	Ideal Goal/Units	
Copper	0.1	0	9/13/17	AL=1.3	0 ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	3	0	9/13/17	AL=15	0 ppb	Corrosion of household plumbing systems; erosion of natural deposits.
Substance	Level Detected	Range	Date Tested	Highest Level Allowed (MCL)	Ideal Goal (MCLG)	Major Source of Contaminant
Alpha emitters	4	ND-4	9/27/16	15	0 pCi/l	Erosion of natural deposits
Fluoride	.48		10/23/18	4	4 ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Haloacetic acids (RAA)	18.9		09/18/18	60	0 ppb	By-product of drinking water chlorination. Results are reported as a running annual average of test results.
Haloacetic Acids* (RAA)*	24.88		11/14/18	60	0 ppm	By-product of drinking water chlorination results are reported as a running annual average of test results.

Total trihalo- methanes* (RAA)	37.75	11/14/18	80	0 ppb	By-product of drinking water chlorination. Results are reported as a running annual average of test results.
Total trihalomethanes (RAA)*	41.3	09/18/18	80	0 ppb	By-product of drinking water chlorination results are reported as a running annual average of test results.

Please direct questions regarding this information to Mr. Tim Jost with the Onida public water system at (605)258-2441.

*Mid-Dakota Rural Water (2175) test result.

The annual consumer confidence report was published in the 4-11-2019 Onida Watchman and residents were notified of this through channel 193 (The Onida news channel).

Published April 11th, 2019 at the total approximate cost of \$